

PART X
TREATMENT TECHNIQUES

§ 1001 GENERAL REQUIREMENTS

These regulations establish treatment techniques in lieu of MCLs for specified contaminants and are considered part of the NNPDWR.

§ 1002 TREATMENT TECHNIQUES FOR ACRYLAMIDE AND EPICHLOROHYDRIN

Each public water system must certify annually in writing to the Director (using third party or manufacturer's certification) that when acrylamide and epichlorohydrin are used in drinking water systems, the combination (or product) of dose and monomer level does not exceed the levels specified as follows:

Acrylamide=0.05% dosed at 1 ppm (or equivalent)

Epichlorohydrin=0.01% dosed at 20 ppm (or equivalent)

Certifications can rely on manufacturers or third parties as approved by the Director.